

**1.0 GENERAL****.1 Requirements Include**

- .1 Firestopping.

**.2 Design Requirements**

- .1 Provide laminated labels at all firestop assembly locations, with the following information included:
  - .1 The words: "*Warning-Through Penetration Firestop System-Do Not Disturb. Notify Building Management of Any Damage.*"
  - .2 Contractor's name, address, and phone number.
  - .3 Through-Penetration firestop system designation of applicable testing and inspecting agency.
  - .4 Date of Installation.
  - .5 Through-Penetration firestop system manufacturer's name.
  - .6 Installer's Name.

**.3 BCIT Submittals and Notifications**

- .1 Submittals:
  - .1 Include in the O&M Manual, ULC systems and all those systems that are not ULC, with Engineer judgment drawings that demonstrate requirements set forth by the International Firestop Council as meeting the Code/Bylaw requirements.

\*\*\* END OF FIRESTOPPING SECTION \*\*\*