

**1.0 GENERAL****.1 Coordination Requirements**

- .1 BCIT Campus Development.

**2.0 ADMINISTRATIVE AND SUBMITTAL REQUIREMENTS****.1 BCIT Submittals and Notifications**

- .1 Shop Drawings:
  - .1 Samples: Submit three (3) samples of each type of sign assembly showing all components and including each exposed fastener type, with required finish, at full scale.

**3.0 MATERIALS****.1 Code Signage**

- .1 Provide Code required signage in accordance with requirements of the Authority Having Jurisdiction.
- .2 Table for common Code Signage requirements:

ITEM - LOCATION	DESCRIPTION
Fire Safety and Exit Route <i>Location indicated.</i> "You are here" drawings	300 x 300 mm (12 x 12 in.), square corners Pressure sensitive vinyl All fastenings to be concealed
"FIRE DOORS KEEP CLOSED" <i>Fire Doors</i>	200 x 200 mm (8 x 8 in.), square corners Black lettering with white background All fastenings to be concealed
"FIRE DOOR DO NOT OBSTRUCT" <i>Fire Doors</i>	200 x 200 mm (8 x 8 in.), square corners Black lettering with white background All fastenings to be concealed
FIRE SAFETY PLAN Shows locations of all required fire extinguishers, fire alarm pull stations, and fire exits. <i>Location per SSEM</i>	Size to fit within 11" x 17" acrylic frame Frame provided by BCIT Safety and Security Emergency Management (SSEM). Coordinate with BCIT SSEM.

**.2 Exterior Signage**

- .1 Contact BCIT Campus Development for further information on Wayfinding Guidelines.

**.3 Interior Signage**

- .1 Contact BCIT Campus Development for Interior Signage requirements and style.

\*\*\* END OF SIGNAGE SECTION \*\*\*